

TECHNICAL DATA

ENCLOSURE :-
EX-d AS PER IS/IEC 60079-1:2007

PROTECTION :-
IP-66 AS PER IS 12063-1987 (IS/IEC 60529:2001)

AREA CLASSIFICATION :-
ZONE -1 & 2

TEMPERATURE CLASS :-
T6

GAS GROUPS :-
IIA, IIB & IIC

MATERIAL OF CONSTRUCTION :-
DIE CAST AL. ALLOY LM-6

HARDWARE :-
STEEL ZINC PLATED/STAINLESS STEEL


FINISH :-
LIGHT GREY | YELLOW
FOR IIA & IIB | FOR IIC

EARTHING :-
1 NO. INSIDE & 2 NOS. OUTSIDE

CABLE ENTRY :-
3/4"ET - 2NOS.

08.	WIRE BUSH	1	GLASSFEEL NYLONE
07.	TERMINAL	A.R.	CLIPON TYPE RAIL MOUNTED
06.	GASKET (ENDLESS, MOULDED)	2	NEOPRENE
05.	CONTACT ELEMENTS (1NC)	1	-
04.	ACTUATOR RED-MUSHROOM HEAD	1	P.P.
03.	TERMINAL BOX COVER	1	DIE CAST AL. ALLOY
02.	MAIN BODY COVER	1	DIE CAST AL. ALLOY
01.	BODY	1	DIE CAST AL. ALLOY
NO.	DESCRIPTION	QTY	MAT./RATING

WIRING DIAGRAM



CLIENT :-	DRAWN	MGP	1.9.16
CONSULTANT :-	CH'D	MGP	1.9.16
P.O.NO. :-	APP'D	NPB	1.9.16

DESCRIPTION:-
FLP WP CONTROL STATION WITH STOP PUSH BUTTON



KAYSONS
TECHNO EQUIPMENTS PVT LTD

1802/7, G.I.D.C. ESTATE,
V.U.NAGAR 388121. (GUJARAT)

SHT.NO.	REV.	DRG.NO.:-
1 OF 1	0	B02

ISSUE	DATE	BY	MODIFICATION
-------	------	----	--------------