

TECHNICAL DATA

ENCLOSURE :-  
EX-d AS PER IS/IEC 60079-1:2007

PROTECTION :-  
IP-66 AS PER IS 12063-1987 (IS/IEC 60529:2001)

AREA CLASSIFICATION :-  
ZONE -1 & 2

TEMPERATURE CLASS :-  
T6

GAS GROUPS :-  
IIA, IIB & IIC

MATERIAL OF CONSTRUCTION :-  
DIE CAST AL. ALLOY LM-6

HARDWARE :-  
STEEL ZINC PLATED/STAINLESS STEEL


FINISH :-  
LIGHT GREY | YELLOW  
FOR IIA & IIB | FOR IIC

EARTHING :-  
1 NO. INSIDE & 2 NOS. OUTSIDE

CABLE ENTRY :-  
3/4"ET - 02NOS.

07.	GASKET (ENDLESS, MOULDED)	2	NEOPRENE
06.	TERMINAL	A.R.	CLIPON TYPE RAIL MOUNTED
05.	WIRE BUSH	1	GLASSFEEL NYLONE
04.	INDICATING LAMP	1	A.R.
03.	TERMINAL BOX COVER	1	DIE CAST AL. ALLOY
02.	MAIN BODY COVER	1	DIE CAST AL. ALLOY
01.	BODY	1	DIE CAST AL. ALLOY
NO.	DESCRIPTION	QTY	MAT./RATING

WIRING DIAGRAM INDICATOR



CLIENT		DRAWN	MLP	DESCRIPTION:- FLP WP CONTROL STATION WITH ONE INDICATING LAMP
CONSULTANT		CH'D	MLP	
P.O.No.		APP'D	MLP	



1802/7, G.I.D.C. ESTATE,  
V.U.NAGAR 388121. (GUJARAT)

SHT.NO.	REV.	DRG.NO.:-
1 OF 1	0	B06

ISSUE	DATE	BY	MODIFICATION
-------	------	----	--------------