

TECHNICAL DATA

ENCLOSURE :-
EX-d AS PER IS/IEC 60079-1:2007

PROTECTION :-
IP-66 AS PER IS 12063-1987 (IS/IEC 60529:2001)

AREA CLASSIFICATION :-
ZONE -1 & 2

TEMPERATURE CLASS :-
T6

GAS GROUPS :-
IIA, IIB & IIC

MATERIAL OF CONSTRUCTION :-
DIE CAST AL. ALLOY LM-6

HARDWARE :-
STEEL ZINC PLATED/STAINLESS STEEL


FINISH :-
LIGHT GREY | YELLOW
FOR IIA & IIB | FOR IIC


EARTHING :-
1 NO. INSIDE & 2 NOS. OUTSIDE

CABLE ENTRY :-
3/4"ET - 02NOS.

07.	GASKET (ENDLESS, MOULDED)	2	NEOPRENE
06.	TERMINAL	A.R.	CLIPON TYPE RAIL MOUNTED
05.	WIRE BUSH	1	GLASSFEEL NYLONE
04.	INDICATING LAMP	2	A.R.
03.	TERMINAL BOX COVER	1	DIE CAST AL. ALLOY
02.	MAIN BODY COVER	1	CAST AL. ALLOY
01.	BODY	1	DIE CAST AL. ALLOY
NO.	DESCRIPTION	QTY	MAT./RATING

WIRING DIAGRAM INDICATOR



CLIENT		DRAWN	MBP	01.09.16	DESCRIPTION:-		
CONSULTANT		CH'D	MBP		FLP WP CONTROL STATION		
P.O.No.		APP'D	MBP		WITH TWO INDICATING LAMP		
 KAYSONS TECHNO EQUIPMENTS PVT LTD		1802/7, G.I.D.C. ESTATE, V.U.NAGAR 388121. (GUJARAT)			SHT.NO. 1 OF 1	REV. 0	DRG.NO.:- B07