



TECHNICAL DATA

ENCLOSURE :-  
EX-d AS PER IS/IEC 60079-1:2007

PROTECTION :-  
IP-66 AS PER IS 12063-1987 (IS/IEC 60529:2001)

AREA CLASSIFICATION :-  
ZONE -1 & 2

TEMPERATURE CLASS :-  
T6

GAS GROUPS :-  
IIA, IIB & IIC

MATERIAL OF CONSTRUCTION :-  
DIE CAST AL. ALLOY LM-6

HARDWARE :-  
STEEL ZINC PLATED/STAINLESS STEEL

FINISH :-  
LIGHT GREY | YELLOW  
FOR IIA & IIB | FOR IIC

EARTHING :-  
1 NO. INSIDE & 2 NOS. OUTSIDE

CABLE ENTRY :-  
3/4"ET - 02NOS.

07.	WIRE BUSH	1	GLASSFEEL NYLONE
06.	TERMINAL	A.R.	CLIPON TYPE RAIL MOUNTED
05.	GASKET (ENDLESS, MOULDED)	2	NEOPRENE
04.	ACTUATOR RED SHROUDED	4	P.P.
03.	TERMINAL BOX COVER	1	DIE CAST AL. ALLOY
02.	MAIN BODY COVER	1	DIE CAST AL. ALLOY
01.	BODY	1	DIE CAST AL. ALLOY
NO.	DESCRIPTION	QTY	MAT./RATING

ISSUE	DATE	BY	MODIFICATION

CLIENT  
CONSULTANT  
P.O.No.

DRAWN *MLP*  
CH'D *MLP*  
APP'D *MLP*

01.09.16

**KAYSONS**  
TECHNO EQUIPMENTS PVT LTD

1802/7, G.I.D.C. ESTATE,  
V.U.NAGAR 388121. (GUJARAT)

DESCRIPTION:-  
FLP WP CONTROL STATION  
WITH PUSH BUTTON

SHT.NO. 1 OF 1  
REV. 0  
DRG.NO.:- B10