



TECHNICAL DATA

ENCLOSURE :-  
EX-d AS PER IS/IEC 60079-1:2007

PROTECTION :-  
IP-66 AS PER IS 12063-1987 (IS/IEC 60529:2001)

AREA CLASSIFICATION :-  
ZONE -1 & 2

TEMPERATURE CLASS :-  
T6

GAS GROUPS :-  
IIA & IIB

MATERIAL OF CONSTRUCTION :-  
DIE CAST AL. ALLOY LM-6

HARDWARE :-  
STEEL ZINC PLATED/STAINLESS STEEL

FINISH :-  
LIGHT GREY POWDER COATED

EARTHING :-  
1 NO. INSIDE & 2 NOS. OUTSIDE

CABLE ENTRY :-  
3/4"ET - 3NOS.

NO.	DESCRIPTION	QTY	MAT./RATING
07.	GASKET (ENDLESS, MOULDED)	2	NEOPRENE
06.	TERMINAL	A.R.	CLIPON TYPE
05.	WIRE BUSH	1	GLASSFEEL NYLONE
04.	INDICATING LAMP	12	A.R.
03.	TERMINAL ENCLOSURE COVER	1	DIE CAST AL. ALLOY
02.	MAIN ENCLOSURE COVER	1	CAST AL. ALLOY
01.	BODY	1	DIE CAST AL. ALLOY

ISSUE	DATE	BY	MODIFICATION

CLIENT :-  
CONSULTANT :-  
P.O.NO. :-

DRAWN MGP 1.9.16  
APP'D HPB 1.9.16  
CH'D NPB 1.9.16

DESCRIPTION:-  
FLP WP. CONTROL STATION WITH INDICATING LAMP

SHT.NO. 1 OF 1  
REV. 0  
DRG.NO.:- B17

**KAYSONS** 1802/7, G.I.D.C. ESTATE,  
TECHNO EQUIPMENTS PVT LTD V.U.NAGAR 388121. (GUJARAT)