



TECHNICAL DATA

ENCLOSURE :-

EX-d AS PER IS/IEC 60079-1:2007

PROTECTION :-

IP-66 AS PER IS 12063-1987 (IS/IEC 60529:2001)

AREA CLASSIFICATION :-

ZONE -1 & 2

TEMPERATURE CLASS :-

T6

GAS GROUPS :-

IIA & IIB

MATERIAL OF CONSTRUCTION :-

DIE CAST AL. ALLOY LM-6

HARDWARE :-

STEEL ZINC PLATED/STAINLESS STEEL

FINISH :-

LIGHT GREY POWDER COATED

EARTHING :-

1 NO. INSIDE & 2 NOS. OUTSIDE

CABLE ENTRY :-

3/4"ET - 3NOS.

09.	GASKET (ENDLESS, MOULDED)	2	NEOPRENE
08.	TERMINAL	A.R.	CLIPON TYPE
07.	WIRE BUSH	1	GLASSFEEL NYLONE
06.	ROTARY SWITCH	1	A.R.
05.	P.B. WITH NO-NC ELEMENTS	4	P.P.
04.	INDICATING LAMP	4	A.R.
03.	TERMINAL ENCLOSURE COVER	1	DIE CAST AL. ALLOY
02.	MAIN ENCLOSURE COVER	1	CAST AL. ALLOY
01.	BODY	1	DIE CAST AL. ALLOY
NO.	DESCRIPTION	QTY	MAT./RATING

CLIENT :-

CONSULTANT :-

P.O.NO. :-

DRAWN MGP 1.9.16

APP'D HPB 1.9.16

CH'D NPB 1.9.16

DESCRIPTION:-

FLP WP. CONTROL STATION WITH
START - STOP P.B., INDICATING LAMP & ROTARY SWITCH



KAYSONS
TECHNO EQUIPMENTS PVT LTD

1802/7, G.I.D.C. ESTATE,
V.U.NAGAR 388121. (GUJARAT)

SHT.NO.
1 OF 1

REV.
0

DRG.NO.:-

B18