



TECHNICAL DATA

ENCLOSURE :-
EX-d AS PER IS/IEC 60079-1:2007

PROTECTION :-
IP-66 AS PER IS 12063-1987 (IS/IEC 60529:2001)

AREA CLASSIFICATION :-
ZONE -1 & 2

TEMPERATURE CLASS :-
T6

GAS GROUPS :-
IIA & IIB

MATERIAL OF CONSTRUCTION :-
DIE CAST AL. ALLOY LM-6

HARDWARE :-
STEEL ZINC PLATED/STAINLESS STEEL

FINISH :-
LIGHT GREY POWDER COATED

EARTHING :-
1 NO. INSIDE & 2 NOS. OUTSIDE

CABLE ENTRY :-
3/4"ET - 3NOS.

07.	GASKET (ENDLESS, MOULDED)	2	NEOPRENE
06.	TERMINAL	A.R.	CLIPON TYPE
05.	WIRE BUSH	1	GLASSFEEL NYLONE
04.	ROTARY SWITCH	5	A.R.
03.	TERMINAL ENCLOSURE COVER	1	DIE CAST AL. ALLOY
02.	MAIN ENCLOSURE COVER	1	CAST AL. ALLOY
01.	BODY	1	DIE CAST AL. ALLOY
NO.	DESCRIPTION	QTY	MAT./RATING

CLIENT :-

CONSULTANT :-

P.O.NO. :-

DRAWN MGP 1.9.16

APP'D HPB 1.9.16

CH'D NPB 1.9.16

DESCRIPTION:-

FLP WP.CONTROL STATION WITH
ROTARY SWITCHES

SHT.NO.
1 OF 1

REV.
0

DRG.NO.:-

B19



KAYSONS
TECHNO EQUIPMENTS PVT LTD

1802/7, G.I.D.C. ESTATE,
V.U.NAGAR 388121. (GUJARAT)