



TECHNICAL DATA

- ENCLOSURE :-  
EX-d AS PER IS/IEC 60079-1:2007
- PROTECTION :-  
IP-66 AS PER IS 12063-1987 (IS/IEC 60529:2001)
- AREA CLASSIFICATION :-  
ZONE -1 & 2
- TEMPERATURE CLASS :-  
T6
- GAS GROUPS :-  
IIA & IIB
- MATERIAL OF CONSTRUCTION :-  
DIE CAST AL. ALLOY LM-6
- HARDWARE :-  
STEEL ZINC PLATED/STAINLESS STEEL
- FINISH :-  
LIGHT GREY POWDER COATED
- EARTHING :-  
1 NO. INSIDE & 2 NOS. OUTSIDE
- CABLE ENTRY :-  
3/4"ET - 3NOS.

07.	GASKET (ENDLESS, MOULDED)	2	NEOPRENE
06.	TERMINAL	A.R.	CLIPON TYPE
05.	WIRE BUSH	1	GLASSFEEL NYLONE
04.	CHANGE OVER/ISOLATOR SWITCH	1	A.R.
03.	TERMINAL ENCLOSURE COVER	1	DIE CAST AL. ALLOY
02.	MAIN ENCLOSURE COVER	1	CAST AL. ALLOY
01.	BODY	1	DIE CAST AL. ALLOY
NO.	DESCRIPTION	QTY	MAT./RATING

CLIENT :-  
CONSULTANT :-  
P.O.NO. :-

DRAWN MGP 1.9.16  
APP'D HPB 1.9.16  
CH'D NPB 1.9.16

DESCRIPTION:-  
FLP WP. CONTROL STATION FOR  
CHANGE OVER/ISOLATOR SWITCH



**KAYSONS**  
TECHNO EQUIPMENTS PVT LTD

1802/7, G.I.D.C. ESTATE,  
V.U.NAGAR 388121. (GUJARAT)

SHT.NO.  
1 OF 1

REV.  
0

DRG.NO.:-  
B20