

TECHNICAL DATA

ENCLOSURE :-

EX-d AS PER IS/IEC 60079-1:2007

PROTECTION :-

IP-66 AS PER IS 12063-1987 (IS/IEC 60529:2001)

AREA CLASSIFICATION :-

ZONE -1 & 2

TEMPERATURE CLASS :-

T6

GAS GROUPS :-

IIA, IIB & IIC

MATERIAL OF CONSTRUCTION :-

DIE CAST AL. ALLOY LM-6

HARDWARE :-

STEEL ZINC PLATED/STAINLESS STEEL

FINISH :-

LIGHT GREY | YELLOW  
FOR IIA & IIB | FOR IIC

EARTHING :-


1 NO. INSIDE & 2 NOS. OUTSIDE

CABLE ENTRY :-

3/4"ET - 02NOS.

08.	GASKET (ENDLESS, MOULDED)	2	NEOPRENE
07.	BEACON	1	A.R.
06.	WIRE BUSH	1	GLASSFEEL NYLONE
05.	6-WAY STRIP	1	A.R.
04.	HOOTER	1	A.R.
03.	BEACON COVER	1	DIE CAST AL. ALLOY
02.	MAIN BODY COVER	1	DIE CAST AL. ALLOY
01.	BODY	1	DIE CAST AL. ALLOY
NO.	DESCRIPTION	QTY	MAT./RATING

ISSUE	DATE	BY	MODIFICATION

CLIENT		DRAWN	MCP	DESCRIPTION:- FLAMEPROOF & WEATHERPROOF HOOTER & BEACON CONTROL STATION
CONSULTANT		CH'D	MCP	
P.O.No.		APP'D	NPB	
 <b>KAYSONS</b> TECHNO EQUIPMENTS PVT LTD		1802/7, G.I.D.C. ESTATE, V.U.NAGAR 388121. (GUJARAT)		SHT.NO. 1 OF 1
01.09.16				REV. 0
DRG.NO.:- C06				DRG.NO.:- C06