



TECHNICAL DATA

ENCLOSURE :-
EX-d AS PER IS/IEC 60079-1:2007

PROTECTION :-
IP-66 AS PER IS 12063-1987 (IS/IEC 60529:2001)

AREA CLASSIFICATION :-
ZONE -1 & 2

TEMPERATURE CLASS :-
T6

GAS GROUPS :-
IIA, IIB & IIC

MATERIAL OF CONSTRUCTION :-
DIE CAST AL. ALLOY LM-6

HARDWARE :-
STEEL ZINC PLATED/STAINLESS STEEL

FINISH :-
RED | YELLOW
FOR IIA & IIB | FOR IIC

EARTHING :-
1 NO. INSIDE & 2 NOS. OUTSIDE

CABLE ENTRY :-
3/4"ET - 02NOS.

10.	GASKET (ENDLESS, MOULDED)	2	NEOPRENE
09.	TERMINAL	A.R.	CLIPON TYPE RAIL MOUNTED
08.	WIRE BUSH	1	GLASSFEEL NYLONE
07.	CONTACT ELEMENT (1NC)	1	-
06.	ACTUATOR SPRING LOADED	1	-
05.	BREAKABLE GLASS	1	-
04.	GLASS HOUSING RING	1	CAST AL. ALLOY
03.	TERMINAL BOX COVER	1	DIE CAST AL. ALLOY
02.	MAIN BODY COVER	1	CAST AL. ALLOY
01.	BODY	1	DIE CAST AL. ALLOY
NO.	DESCRIPTION	QTY	MAT./RATING

ISSUE	DATE	BY	MODIFICATION	CLIENT	CONSULTANT	P.O.No.	DRAWN	MCP	CH'D	MCP	APP'D	NPB	DESCRIPTION:-		
													FLAMEPROOF WEATHERPROOF FIRE ALARM STATION		
							KAYSONS TECHNO EQUIPMENTS PVT LTD			1802/7, G.I.D.C. ESTATE, V.U.NAGAR 388121. (GUJARAT)			SHT.NO.	REV.	DRG.NO.:-
										1 OF 1			0	D02	