



TECHNICAL DATA

ENCLOSURE :-  
EX-d AS PER IS/IEC 60079-1:2007

PROTECTION :-  
IP-66 AS PER IS 12063-1987 (IS/IEC 60529:2001)

AREA CLASSIFICATION :-  
ZONE -1 & 2

TEMPERATURE CLASS :-  
T6

GAS GROUPS :-  
IIA & IIB

MATERIAL OF CONSTRUCTION :-  
DIE CAST AL. ALLOY LM-6

HARDWARE :-  
STEEL ZINC PLATED/STAINLESS STEEL

FINISH :-  
LIGHT GREY POWDER COATED

EARTHING :-  
1 NO. INSIDE & 2 NOS. OUTSIDE

CABLE ENTRY :-  
3/4"ET - 3NOS.

09.	GASKET (ENDLESS, MOULDED)	2	NEOPRENE
08.	TERMINAL	A.R.	CLIPON TYPE
07.	AMMETER (GLASS WINDOW)	1	64mmX64mm
06.	ACTUATOR RED-MUSHROOM HEAD	1	P.P.
05.	ACTUATOR GREEN-SHROUDED	1	P.P.
04.	WIRE BUSH	1	GLASSFEEL NYLONE
03.	TERMINAL ENCLOSURE COVER	1	DIE CAST AL. ALLOY
02.	MAIN ENCLOSURE COVER	1	DIE CAST AL. ALLOY
01.	BODY	1	DIE CAST AL. ALLOY
NO.	DESCRIPTION	QTY	MAT./RATING

ISSUE	DATE	BY	MODIFICATION

CLIENT		DRAWN	MSP	DESCRIPTION:- FLP WP. CONTROL STATION START-STOP P.B. WITH AMMETER
CONSULTANT		CH'D	MSP	
P.O.No.		APP'D	MSP	
		1802/7, G.I.D.C. ESTATE, V.U.NAGAR 388121. (GUJARAT)		SHT.NO. 1 OF 1
07.09.16				REV. 0
DRG.NO.:- K07				