



TECHNICAL DATA

ENCLOSURE :-  
EX-d AS PER IS/IEC 60079-1:2007

PROTECTION :-  
IP-66 AS PER IS 12063-1987 (IS/IEC 60529:2001)

AREA CLASSIFICATION :-  
ZONE -1 & 2

TEMPERATURE CLASS :-  
T6

GAS GROUPS :-  
IIA & IIB

MATERIAL OF CONSTRUCTION :-  
DIE CAST AL. ALLOY LM-6

HARDWARE :-  
STEEL ZINC PLATED/STAINLESS STEEL

FINISH :-  
LIGHT GREY POWDER COATED

EARTHING :-  
1 NO. INSIDE & 2 NOS. OUTSIDE

CABLE ENTRY :-  
3/4"ET - 3NOS.

NO.	DESCRIPTION	QTY	MAT./RATING
09.	GASKET (ENDLESS, MOULDED)	2	NEOPRENE
08.	TERMINAL	A.R.	CLIPON TYPE
07.	INDICATING LAMP	1	A.R.
06.	AMMETER (GLASS WINDOW)	1	64mmX64mm
05.	SWITCH	2	A.R.
04.	WIRE BUSH	1	GLASSFEEL NYLONE
03.	TERMINAL ENCLOSURE COVER	1	DIE CAST AL. ALLOY
02.	MAIN ENCLOSURE COVER	1	DIE CAST AL. ALLOY
01.	BODY	1	DIE CAST AL. ALLOY

ISSUE	DATE	BY	MODIFICATION	CLIENT	CONSULTANT	P.O.No.	DRAWN	CH'D	APP'D	DESCRIPTION:-	SHT.NO.	REV.	DRG.NO.:-
							MSP	MSP	NPB	FLP WP. CONTROL STATION PUSH LAMP.SWITCH & AMMETER.	1 OF 1	0	K09



**KAYSONS**  
TECHNO EQUIPMENTS PVT LTD

1802/7, G.I.D.C. ESTATE,  
V.U.NAGAR 388121. (GUJARAT)

08.09.16