



TECHNICAL DATA

ENCLOSURE :-
EX-d AS PER IS/IEC 60079-1:2007

PROTECTION ;-
IP-66 AS PER IS 12063-1987 (IS/IEC 60529:2001)

AREA CLASSIFICATION :-
ZONE -1 & 2

TEMPERATURE CLASS :-
T6

GAS GROUPS :-
IIA & IIB

MATERIAL OF CONSTRUCTION :-
DIE CAST AL. ALLOY LM-6

HARDWARE :-
STEEL ZINC PLATED/STAINLESS STEEL

FINISH :-
LIGHT GREY

EARTHING :-
1 NO. INSIDE & 2 NOS. OUTSIDE

CABLE ENTRY :-
3/4"ET - 3NOS.

NO.	DESCRIPTION	QTY	MAT./RATING
08.	GASKET (ENDLESS, MOULDED)	2	NEOPRENE
07.	TERMINAL	A.R.	CLIPON TYPE
06.	ACTUATOR BLACK-SHROUDED	4	P.P.
05.	AMMETER (GLASS WINDOW)	1	88mmX88mm
04.	WIRE BUSH	1	GLASSFEEL NYLONE
03.	TERMINAL ENCLOSURE COVER	1	DIE CAST AL. ALLOY
02.	MAIN ENCLOSURE COVER	1	CAST AL. ALLOY
01.	BODY	1	DIE CAST AL. ALLOY

ISSUE	DATE	BY	MODIFICATION	CLIENT	CONSULTANT	P.O.No.	DRAWN	CH'D	APP'D	DESCRIPTION:-	
							MSP	MSP	NPB	FLP WP. CONTROL STATION PUSH BUTTON & AMMETER.	
				KAYSONS TECHNO EQUIPMENTS PVT LTD			1802/7, G.I.D.C. ESTATE, V.U.NAGAR 388121. (GUJARAT)		SHT.NO. 1 OF 1 REV. 0 DRG.NO.:- K11		